

LEAD AND COPPER SAMPLE REPORT

PWS ID	SYSTEM NAME	Site ID	lab no	analyte	test date	Result	unit
566	Tontitown Waterworks	566YL002	07101709	Lead	10/31/2006	< 0.003	mg/L
566	Tontitown Waterworks	566YL	07101709	Copper	10/31/2006	< 0.20	mg/L
566	Tontitown Waterworks	566YL004	07101710	Lead	10/31/2006	0.002	mg/L
566	Tontitown Waterworks	566YL	07101710	Copper	10/31/2006	< 0.20	mg/L
566	Tontitown Waterworks	566YL014	07101711	Lead	10/31/2006	< 0.003	mg/L
566	Tontitown Waterworks	566YL	07101711	Copper	10/31/2006	< 0.20	mg/L
566	Tontitown Waterworks	566YL015	07101712	Lead	10/31/2006	< 0.003	mg/L
566	Tontitown Waterworks	566YL	07101712	Copper	10/31/2006	< 0.20	mg/L
566	Tontitown Waterworks	566YL019	07101713	Lead	10/31/2006	< 0.003	mg/L
566	Tontitown Waterworks	566YL	07101713	Copper	10/31/2006	< 0.20	mg/L
566	Tontitown Waterworks	566YL021	07101714	Lead	10/31/2006	< 0.003	mg/L
566	Tontitown Waterworks	566YL	07101714	Copper	10/31/2006	< 0.20	mg/L
566	Tontitown Waterworks	566YL026	07101715	Lead	10/31/2006	< 0.003	mg/L
566	Tontitown Waterworks	566YL	07101715	Copper	10/31/2006	< 0.20	mg/L
566	Tontitown Waterworks	566YL030	07101716	Lead	10/31/2006	< 0.003	mg/L
566	Tontitown Waterworks	566YL	07101716	Copper	10/31/2006	< 0.20	mg/L

